



Upper Occoquan Service Authority

Leader in Water Reclamation and Reuse

14631 COMPTON ROAD, CENTREVILLE, VIRGINIA 20121-2506
(703) 830-2200

To All RFQ Recipients:

July 10, 2019

For UOSA **RFQ# 19-15**; Furnish and Deliver Polymer Activation Unit

Subject: Addendum # 1

The above referenced solicitation is amended as set forth below. The hour and date specified for receipt of Quotes:

| **X** | is not extended;

| | is extended;

Description of Addendum

- A. Answers to questions received prior to the deadline for questions
 - B. Replacement Quote Summary Sheet
-

A. Questions and Answers

1. Q: Is the water flow rate of 0-600 GPH correct? Based on the neat polymer pump capacity of 60 GPH (paragraph 2.2) and solution concentration of 0.5% to 1% (paragraph 2.5), it seems the required water flow rate is 12,000 GPH.?

A: 1. The water flow rate should be 0-6,000 GPH for the primary dilution and 6,000 GPH of post dilution water.

2. Q: Attachment C; Item 2: What is the “Required Annual Service Agreement”? Where is it described in the specification?

A: A replacement Quote Summary Sheet has been provided which removes the Required Annual Service Agreement line.

B. Replacement Quote Summary Sheet

The Quote Summary Sheet attached to this addendum shall supersede and replace Attachment C in the original solicitation in its entirety.

All other Terms, Conditions, Tables, Charts and Specifications, and Drawings not otherwise changed remain as originally stated or as shown. Acknowledge your receipt of, and compliance with, this Addendum #1 by signing it and submitting it with your Quote, or referencing its receipt and your compliance in your cover letter.

ISSUED BY:

Upper Occoquan Service Authority

Dustin Baker, Buyer, CPPB

ACKNOWLEDGED BY:

Company/Offeror Name

Signature of Authorized Agent

Date

Printed/Typed Name

ATTACHMENT C: QUOTE SUMMARY SHEET – Updated Version Included with RFQ 19-15 Addendum #1

All costs - labor, materials, equipment rental, travel, freight (to Centreville VA), etc. must be included in the price totals provided. Additional charges not included in the quote may not be considered.

Item	QTY	Description of Requirement	Proposed Equipment/Service	Price
1	1	Complete Polymer Activation Unit		\$
2		Optional Service Agreements, Maintenance Agreements, Extended Warranties, Software Upgrades, etc.		\$ /
				\$ /
				\$ /

*Provide detailed specifications, cut sheets, engineering drawings, etc. as necessary to indicate that the proposed equipment meets all RFQ requirements.

Expected lead time for complete delivery of all requested materials after receipt of Purchase Order: _____ days

Discount Payment Terms if applicable shall be _____%, _____, Net _____ Days
 (Please note any prompt payment discount payment offered, i.e.2%10, Net 30 Days)

.....
 In compliance with this Request for Quote and to all the terms, conditions, and Specifications imposed therein and hereby incorporated by reference, the undersigned offers and agrees to furnish the goods and/or services described herein.

Company Name: _____ Date: _____

Authorized Signature: _____

Printed Name: _____ Title: _____

Telephone: _____ Fax: _____

**This form must be included with your submission.
 End Attachment C**