



Upper Occoquan Service Authority

Leader in Water Reclamation and Reuse

14631 COMPTON ROAD, CENTREVILLE, VIRGINIA 20121-2506
(703) 830-2200

To All IFB Recipients:

August 21, 2019

For UOSA **IFB# 20-02**; Bar Screen Replacements

Subject: Addendum # 1

The above referenced solicitation is amended as set forth below. The hour and date specified for receipt of Bids:

| **X** | is not extended;

| | is extended;

Description of Addendum

A. Answers to questions asked during pre-bid meeting. Note, no questions were received in writing prior to the deadline for questions.

A. Questions and Answers

1. Q: Will the contractor be required to supply any new control equipment?
A: No, the contractor will only be responsible for making connections between the new bar screen and existing control equipment.
2. Q: Will the contractor need to re-square the frames?
A: No
3. Q: Will the contractor be responsible for applying any coatings or paint to the bar screen?
A: No
4. Q: Will UOSA provide the necessary Hilti adhesives and ensure that they are not expired?
A: UOSA has the necessary adhesives currently on-site and they do not expire until 02/2020.
5. Q: What is the weight of the carriage?
A: The weight is estimated to be 1490 lbs. according to the drawings.

All other Terms, Conditions, Tables, Charts and Specifications, and Drawings not otherwise changed remain as originally stated or as shown. Acknowledge your receipt of, and compliance with, this Addendum #1 by signing it and submitting it with your Bid, or referencing its receipt and your compliance in your cover letter.

ISSUED BY:

Upper Occoquan Service Authority



Dustin Baker, Buyer, CPPB

ACKNOWLEDGED BY:

Company/Offeror Name

Signature of Authorized Agent

Date

Printed/Typed Name