



# Upper Occoquan Service Authority

*Leader in Water Reclamation and Reuse*

14631 COMPTON ROAD, CENTREVILLE, VIRGINIA 20121-2506  
(703) 830-2200

**TO ALL IFB RECIPIENTS:**

**For UOSA IFB 25-08 Furnish and Deliver Granular Media to Remove H2S**

**SUBJECT: Addendum # 2**

The above numbered solicitation is amended as set forth below. The hour and date specified for receipt of offers:

is not extended

is extended

**OFFERORS MUST ACKNOWLEDGE** receipt of this Addendum by one of the following methods:

- a. By acknowledgement of this Addendum on Submission Form submitted with the proposal;
- b. By referencing its receipt in your Transmittal Letter

If by virtue of this Addendum you desire to change a proposal already submitted, such change may be made by letter, provided it includes reference to the solicitation and this Addendum and is received prior to the due hour and date specified.

**DESCRIPTION OF ADDENDUM:**

1. This addendum is being issued to fully address question # 7 from Addendum #1 which was not answered completely. Question 7 contained two parts and the second part was: ***Do you have the ability and would you be willing to add/inject oxygen into the stream prior to the treatment vessels should the levels in fact be 0%.***  
The answer to the question is as follows: ***No, UOSA cannot commit to maintaining oxygen levels above 0%.***

---

*All other Terms, Conditions, Tables, Charts and Specifications, and Drawings not otherwise changed remain as originally stated or as shown.*

**ISSUED BY:**

Upper Occoquan Service Authority

  
Dustin Baker, Purchasing Manager      2/11/2025  
Date