



# Upper Occoquan Service Authority

*Leader in Water Reclamation and Reuse*

14631 COMPTON ROAD, CENTREVILLE, VIRGINIA 20121-2506  
(703) 830-2200

## TO ALL IFB RECIPIENTS:

**For UOSA IFB 25-13 Furnish Deliver and Install Evaporator and Condensing Unit**

## SUBJECT: Addendum # 2

The above numbered solicitation is amended as set forth below. The hour and date specified for receipt of offers:

☒ is not extended

☐ is extended

**OFFERORS MUST ACKNOWLEDGE** receipt of this Addendum by one of the following methods:

- a. By acknowledgement of this Addendum on Submission Form submitted with the proposal;
- b. By referencing its receipt in your Transmittal Letter

If by virtue of this Addendum you desire to change a proposal already submitted, such change may be made by letter, provided it includes reference to the solicitation and this Addendum and is received prior to the due hour and date specified.

## DESCRIPTION OF ADDENDUM:

UOSA will accept R-454B as an approved refrigerant. The following sentence shall replace the second sentence in Section 2.1.1:


*R-410 refrigerant (R454-B will also be accepted as an approved alternate refrigerant), service valves, non-fused disconnect, and 5-year compressor parts warranty.*

---

*All other Terms, Conditions, Tables, Charts and Specifications, and Drawings not otherwise changed remain as originally stated or as shown.*

## ISSUED BY:

Upper Occoquan Service Authority

  
\_\_\_\_\_  
Dustin Baker, Purchasing Manager

07/14/2025

Date