

**ADDENDUM No.2
to the
IFB 27-01 Contract Documents
for the construction of
GAC Treatment Optimization (UOSA Contract L2 GAC)**

Date: September 29, 2026

To: All Official Bidding Document Planholders:

The following changes, additions, and/or deletions are hereby made part of the Contract Documents for the construction of UOSA Contract L2 GAC for the Upper Occoquan Service Authority, Centreville, Virginia, as fully and completely as if the same were set forth therein:

A. BIDDING REQUIREMENTS

No Change

B. CONTRACT FORMS

No Change

C. CONDITIONS OF THE CONTRACT

No Change

D. SPECIFICATIONS

No Change

E. DRAWINGS

No Change

INTERPRETATIONS AND CLARIFICATIONS:

Pursuant to the Instructions to Bidders, Article 1.B, the following interpretations and

clarifications are offered in response to questions from potential bidders and other interested parties. These responses are intended to clarify, not change, the terms, conditions, and scope of the Work.

1. **Question:** Please clarify whether the work specified under Section 03 01 30.71 – Modifications to Existing Concrete is intended to be included within Bid Form Item 3 – Concrete Repair Allowance. If the work specified under Section 03 01 30.71 is not included in the Bid Form Item 3 concrete repair allowance, please provide the quantity of concrete modifications shown on Drawing SD-1, Details C & D to be performed so that this work can be properly included in the bid.

Answer: Section 03 01 30.71 “Modifications to Existing Concrete” applies to any work where existing concrete is modified or repaired which will be paid for through Bid Form Item 3 Concrete Repair Allowance.

2. **Question:** The Specification Section 46 61 13 requires the existing underdrain nozzles to be removed, inspected, and either reused, modified/retrofitted, or replaced as determined by the Engineer. Since the quantity of nozzles requiring replacement cannot be determined until the inspection is performed, we request that the underdrain nozzle replacement be carried as a unit price item. Please also confirm whether the unit price should be provided per nozzle or per 100 nozzles.

Answer: No unit price for replacement underdrain nozzles is required. In accordance with Section 01 11 00 “Summary of Work”, Paragraph 1.5, B, 1, c, UOSA will furnish any replacement underdrain nozzles required, and the Contractor shall include in the base bid all labor, equipment, and incidental materials necessary to remove existing nozzles and install the nozzles provided by UOSA. Contractor to remove the existing nozzles and transmit them to UOSA for future use, including subsequent Work. UOSA will provide all nozzles to be installed in all contractors.

ATTACHMENTS: Exhibit A – Current Plan Holder List

All other Terms, Conditions, Tables, Charts and Specifications, and Drawings not otherwise changed remain as originally stated or as shown.

ISSUED BY:

Upper Occoquan Service Authority

 9/29/2026
 Dustin Baker, Purchasing Manager Date

End of Addendum No. 2

UOSA IFB 27-01 L2 GAC Addendum #2 Exhibit A

UOSA IFB 27-01 L2 GAC Plan Holders List
As of 9/29/2026

<u>Vendor</u>	<u>Street</u>	<u>City/State/Zip</u>
W.M. Schlosser	2400 51st Place	Hyattsville, MD 20781
Baker Contracting	2101 Wilson Blvd, #100	Arlington, VA 22201
Norair	337 Brightseat Rd., Suite 200	Landover, MD 20785
Morgan Contracting	900 Dutch Valley Drive	Knoxville, TN 37918
CPP Construction	26 North Summit Avenue	Gaithersburg, MD 20877
Walsh Group/Archer Western	13454 Sunrise Valley Drive, Suite 440	Herndon, VA 20171
Rasco, Inc.	1635-2 Woodside Drive	Woodbridge, VA 22191
Calgon Carbon	3000 GSK Drive	Moon Township, PA 15108
All Service Contracting Corp	2024 E. Damon Ave	Decatur, IL 62526
MC Dean	199 Sulky Dr, Suite 3	Winchester, VA 22602
Norit	3200 University Ave	Marshall, TX 75670, USA
Maverick Regan	401 Greenwood Creek Lane	Grasonville, MD 21638